


Schedule of Accreditation

issued by

United Kingdom Accreditation Service

2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

| | | |
|--|--|---|
|  <p>6123 Type C Inspection Body Accredited to ISO/IEC 17020:2012</p> | SOCOTEC UK Limited Issue No:007 Issue date: 30 October 2025 | |
| | SOCOTEC House Bretby Business Park Ashby Road Bretby Burton upon Trent Staffordshire DE15 0YZ | Contact: Mrs R Hobson Tel: +44 (0)1283 554400 Fax: +44 (0)1283 554422 E-Mail: accreditations@socotec.com Website: www.socotec.co.uk |
| Inspection performed at/from the above address only | | |

DETAIL OF ACCREDITATION

| Field of Inspection | Type and Range of Inspection | Methods and Procedures |
|-----------------------------|--|---|
| Legionella Risk assessments | Cooling towers Domestic hot/cold systems, Spa pools Other systems containing water which is likely to exceed 20°C which may release a spray or aerosol during operation of when being maintained Water Sampling for the purpose of legionella risk assessments: Legionella, TVC, Coliforms, E. Coli and pseudomonas aeruginosa Water testing for the purpose of Legionella risk assessment: Temperature | Documented In-House Methods Manual, based on ACoP L8 and BS 8580-1:2019 Method ENV 500 Method ENV 458 Method ENV 452 |
| END | | |