


Schedule of Accreditation

issued by

United Kingdom Accreditation Service

2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

 <p>7826 Type C Inspection Body</p> <p>Accredited to ISO/IEC 17020:2012</p>	<p>Water Hygiene Centre Ltd</p> <p>Issue No: 011 Issue date: 05 January 2026</p>	
	<p>6-7 Southill Business Park Cornbury Park Charlbury Oxfordshire OX7 3EW</p>	<p>Contact: Mr Chris Lawry Tel: +44 (0)1993 840400 E-Mail: Chris.Lawry@waterhygienecentre.com Website: www.waterhygienecentre.com</p>
<p>Inspection performed at/from the above location only</p>		

DETAIL OF ACCREDITATION

Field of Inspection	Type and Range of Inspection	Methods and Procedures
Legionella Risk Assessments (including health and social care settings)	<p>Artificial water risk system:</p> <ul style="list-style-type: none"> • Hot/cold systems • Spa baths and hydrotherapy pools • Other systems containing water which is likely to exceed 20°C which may release a spray or aerosol during operation or when being maintained <p>Water testing for the purpose of Legionella risk assessment:</p> <ul style="list-style-type: none"> • Temperature <p>Testing may be reported only as part of a risk assessment report in support of the Legionella risk assessment.</p>	<p>Documented In-House Methods, based on the requirements of ACoP L8 and BS 8580-1:2019</p> <p>In house method 1 (PDSRAP01)</p> <p>In house method 3 (PDSHCP01)</p>
<p>END</p>		