

# Schedule of Accreditation

issued by

## United Kingdom Accreditation Service

2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK



1632

Accredited to  
ISO/IEC 17025:2017

### Charles Darley and Associates Limited

Issue No: 013      Issue date: 06 May 2021

33 Campbell Street  
Helensburgh  
G84 8XZ

Contact: Dr J C Darley  
Tel: +44 (0)1436 673805  
Fax: +44 (0)1436 674109  
E-Mail: charles@charlesdarley.com

Testing performed by the Organisation at the locations specified below

Locations covered by the organisation and their relevant activities

Site activities performed away from the locations listed above:

| Location details   | Activity   | Location code |
|--|--|---------------|
| Any Customer Premises - all locations suitable for the activities listed | Sampling:<br>Concrete (hardened)& Grout<br><br>Testing:<br>Concrete (hardened) - chemical tests<br>Concrete (reinforced) - non-destructive tests | Site          |



1632  
Accredited to  
ISO/IEC 17025:2017

**Schedule of Accreditation**  
issued by  
**United Kingdom Accreditation Service**  
2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

**Charles Darley and Associates Limited**  
**Issue No: 013 Issue date: 06 May 2021**

Testing performed by the Organisation at the locations specified

DETAIL OF ACCREDITATION

| Materials/Products tested         | Type of test/Properties measured/Range of measurement          | Standard specifications/ Equipment/Techniques used | Location Code |
|-----------------------------------|--|--|---------------|
| CONCRETE - hardened               | Coring   | BS EN 12504-1:2019                                 | Site          |
|                                   | Sampling of concrete by drilling                               | TRL Contractors Report 32, 1986                    | Site          |
|                                   | Carbonation  | BS EN 14630:2006                                   | Site          |
| CONCRETE - reinforced             | Location of reinforcement - up to 100mm cover                  | BS 1881-204:1988                                   | Site          |
|                                   | Corrosion potentials of uncoated reinforcing steel in concrete | ASTM C876-15                                       | Site          |
| CONCRETE BRIDGES - post-tensioned | Sampling of tendon grout material                              | Documented In-House Method STPM 6:2021             | Site          |
| END                               |  |  |               |