


Schedule of Accreditation

issued by

United Kingdom Accreditation Service

2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

 <p>0330</p> <p>Type C Inspection Body</p> <p>Accredited to ISO/IEC 17020:2012</p>	<p>Assurity Consulting Ltd</p> <p>Issue No: 006 Issue date: 26 November 2019</p>	
	<p>26 Redkiln Way Horsham West Sussex RH13 5QH</p>	<p>Contact: Ms Y Goodey Tel: +44 (0)1403 269375 E-Mail: Yvonne.Goodey@assurityconsulting.co.uk Website: www.assurityconsulting.co.uk</p>
<p>Inspection performed at/from the above address only</p>		

DETAIL OF ACCREDITATION

Field of Inspection	Type and Range of Inspection	Methods and Procedures
Legionella Risk Assessments	<p><u>Artificial water risk system:</u></p> <ul style="list-style-type: none"> • Cooling towers • Evaporative condensers • Hot/cold systems • Other high risk systems generating a fine spray or aerosol, as specified in the in house procedure <p>Water sampling for the purpose of Legionella risk assessments for subsequent Microbiological and chemical analysis:</p> <ul style="list-style-type: none"> • Total viable count • <i>Legionella spp</i> <p>Water testing for the purpose of Legionella risk assessment:</p> <ul style="list-style-type: none"> • pH • Electrical conductivity • Bromine • Temperature <p>Sampling and testing may be reported only as part of a risk assessment report in support of the Legionella risk assessment</p>	<p>Documented In-House Method OM-D4-045 based on BS 8580-1:2019 and ACoP L8</p> <p>Documented in house methods W1, W7</p> <p>Documented in house methods W1, W5</p>
<p>END</p>		