

# Schedule of Accreditation

issued by

## United Kingdom Accreditation Service

2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

 <p><b>6123</b> <b>Type C</b> <b>Inspection Body</b></p> <p>Accredited to ISO/IEC 17020:2012</p>	<b>SOCOTEC UK Limited</b>  <b>Issue No: 005    Issue date: 2 January 2018</b>	
	<b>SOCOTEC House</b> <b>Bretby Business Park</b> <b>Ashby Road</b> <b>Bretby</b> <b>Burton upon Trent</b> <b>Staffordshire</b> <b>DE15 0YZ</b>	<b>Contact: Mr A.Watkinson</b> <b>Tel: +44 (0)1283 554400</b> <b>Fax: +44 (0)1283 554422</b> <b>E-Mail: <a href="mailto:accreditations@socotec.com">accreditations@socotec.com</a></b> <b>Website: <a href="http://www.socotec.co.uk">www.socotec.co.uk</a></b>
<b>Inspection performed at/from the locations specified below</b>		

### Locations covered by the organisation and their relevant activities

Location details	Activity	Location code
<p><b>Address</b> SOCOTEC House Bretby Business Park Ashby Road Bretby Burton upon Trent Staffs DE15 0YZ</p> <p><b>Local contact</b> Mr P.Sear  Tel: +44 (0)1283 554400 Fax: +44 (0)1283 554422 Email: <a href="mailto:salesuk@socotec.com">salesuk@socotec.com</a></p>	<p><b>Inspection Activities:</b></p>	A
<p><b>Address</b> 2-8 Langlands Place Kelvin South Business Park East Kilbride G75 0YF</p> <p><b>Local contact</b> Mr D.Gilmour  Tel: +44 (0)7949645479 Fax: +44 (0)1355 246730 Email: <a href="mailto:salesuk@socotec.com">salesuk@socotec.com</a></p>	<p><b>Inspection Activities:</b></p>	B
<p><b>Address</b> Unit D 2 Wilkinson Road Bankside Business Park Cirencester Gloucestershire GL7 1YT</p> <p><b>Local contact</b> Mr K.Woods  Tel: +44 (0)1285 700593 Email: <a href="mailto:salesuk@socotec.com">salesuk@socotec.com</a></p>	<p><b>Inspection Activities:</b></p>	C



6123

Type C  
Inspection Body

Accredited to  
ISO/IEC 17020:2012

**Schedule of Accreditation**  
issued by  
**United Kingdom Accreditation Service**  
2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

**SOCOTEC UK Limited**

**Issue No: 005 Issue date: 2 January 2018**

Inspection performed at/from main address only

DETAIL OF ACCREDITATION

Field of Inspection	Type and Range of Inspection	Methods and Procedures	Location Code
Legionella Risk assessments	Cooling towers Domestic hot/cold systems, Spa pools Other systems containing water which is likely to exceed 20°C which may release a spray or aerosol during operation of when being maintained	Documented In-House Methods Manual, based on ACoP L8 and BS 8580:2010  Method ENV 500	A,B,C
	Water Sampling for the purpose of legionella risk assessments:  legionella, TVC, Coliforms, E. Coli and pseudomonas aeruginosa	Method ENV 458	A,B,C
	Water testing for the purpose of Legionella risk assessment:  temperature	Method ENV 452	A,B,C
END			