


Schedule of Accreditation

issued by

United Kingdom Accreditation Service

2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

 <p>UKAS INSPECTION</p> <p>7775</p> <p>Type C Inspection Body</p> <p>Accredited to ISO/IEC 17020:2012</p>	<h3>Hydrop Environmental Consultancy Services</h3> <p>Issue No: 007 Issue date: 23 August 2023</p>	
	<p>Wrens Court 55 Lower Queen Street Sutton Coldfield B72 1RT</p>	<p>Contact: Mr E Koumi Tel: +44 (0)121 354 2030 Fax: +44 (0)121 354 8030 E-Mail: info@hydrop.com Website: www.hydrop.com</p>
<p>Inspection performed at/from the above address only</p>		

DETAIL OF ACCREDITATION

Field of Inspection	Type and Range of Inspection	Methods and Procedures
Legionella Risk Assessments (including health and social care settings)	<p>Artificial Water System:</p> <ul style="list-style-type: none"> • Cooling towers • Evaporative Condensers • Domestic hot/cold systems • Spa pools • Other systems containing water which is likely to exceed 20°C which may release a spray or aerosol during operation or when being maintained (as specified in the in-house procedure) <p>Water sampling (reported only as part of a risk assessment report for the purpose of Legionella risk assessment), for subsequent Microbiological analysis:</p> <ul style="list-style-type: none"> • Aerobic Colony Count • <i>Legionella</i> <p>Indicative water testing for the purpose of Legionella risk assessment:</p> <ul style="list-style-type: none"> • Temperature 	<p>Documented In-House Method HYD17020M Appendix 1 and HYP031 based on ACoP L8 and BS 8580-1:2019</p> <p>Documented In-House Method HYP031</p>
<p>END</p>		