


Schedule of Accreditation

issued by

United Kingdom Accreditation Service

2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

 <p>7826 Type C Inspection Body</p> <p>Accredited to ISO/IEC 17020:2012</p>	<h3>Water Hygiene Centre Limited</h3> <p>Issue No: 008 Issue date: 16 August 2021</p>	
	<p>4 Southill Business Park Cornbury Park Charlbury Oxfordshire OX7 3EW</p>	<p>Contact: Mr Chris Lawry Tel: +44 (0)1993 840400 E-Mail: Chris.Lawry@waterhygienecentre.com Website: www.waterhygienecentre.com</p>
<p>Inspection performed at/from the above location only</p>		

DETAIL OF ACCREDITATION

Field of Inspection	Type and Range of Inspection	Methods and Procedures	
Legionella Risk Assessments	Artificial water risk system:	Documented In-House Methods, based on the requirements of ACoP L8: 2013 and BS 8580-1:2019	
	<ol style="list-style-type: none"> 1. Domestic hot / cold systems irrespective of size in premises 2. Spa baths and hydrotherapy pools in which warm water is deliberately agitated and re-circulated 3. Humidifiers and air washers which create a spray of water droplets and in which the water temperature is likely to exceed 20°C 4. Outlets generating a fine spray or aerosol i.e. sprays taps or hoses 	In house method 1 (PDSRAP01)	
	Water sampling for the purpose of Legionella risk assessments, for subsequent analysis; <i>Legionella spp</i> ,		In house method 2 (PDSSAP04)
	Water testing for the purpose of Legionella risk assessment: Temperature		In house method 3 (PDSHCP01)
<p>Sampling and testing may be reported only as part of a risk assessment report in support of the Legionella risk assessment.</p>			
<p>END</p>			